

Certificate of Compliance

Certificate: 2165814

Project: 2744039

Issued to: Exlar Corporation

18400 West 77th St Chanhassen, MN 55317 USA Attention: Gene Larson Master Contract: 163694

Date Issued:

September 17, 2014

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to US Standards
CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Division 1, Groups B, C and D;

-EXP-24-20 controller, input rated 20Vdc to 28Vdc, 27A peak; Ambient Temperature Range: -29°C to 82 °C; Temperature Code T5; Enclosure Type 4.

-EXP-120-5 controller, input rated 120Vdc nominal (150Vdc max), 4.5A max; Ambient Temperature Range: -29°C to 82 °C; Temperature Code T5; Enclosure Type 4.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 0-M1991 - General Requirements - Canadian Electrical Code Part II

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations



Certificate:	2165814	Master Contract:	163694
Project:	2744039	Date Issued:	September 17, 2014

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CAN/CSA Std C22.2 No. 94-M1991 - Special Purpose Enclosures

UL Std No. 1203-2006 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

UL Std No. 916-1998 - Energy Management Equipment

UL Std No. 50-2003 - Enclosures for Electrical Equipment